




California ISO  
Shaping a Renewed Future

# Energy Storage Interconnection Initiative


Stakeholder Meeting  
August 13, 2014



# Agenda

Time	Agenda Item	Speaker
10:00-10:05	Introduction, Stakeholder Process	Tom Cuccia
10:05-10:30	Background / Updates	Tom Flynn
10:30-11:30	Applying the GIDAP to Cluster 7	Tom Flynn / Songzhe Zhu
11:30-12:00	Review of existing processes for project modification	Debi Le Vine
12:00-1:00	Lunch break	
1:00-2:45	Resource adequacy-related interconnection issues	Karl Meeusen
2:45-3:00	Next Steps	Tom Cuccia

# ISO Stakeholder Initiative Process



**We Are Here**

# Stakeholder process schedule

Step	Date	Event
Round 1	June 24	Post issue paper & straw proposal
	July 1	Stakeholder web conference
	July 15	Stakeholder comments due
Round 2	August 13	Stakeholder meeting
	August 20	Stakeholder comments due
Round 3	September 16	Post paper #2
	September 23	Stakeholder web conference
	October 7	Stakeholder comments due
Board approval (only if needed)	November 13-14	ISO Board meeting

# Background / Updates

# Interest in storage is accelerating

- In October 2013, the CPUC adopted an energy storage procurement framework.
  - Established a target of 1,325 MW of energy storage to be procured by PG&E, SCE, and SDG&E by 2020, with installations required no later than the end of 2024.
- In April 2014, the ISO received interconnection requests for over 2,300 MW of energy storage in Queue Cluster 7.
  - 1,342 MW of stand-alone storage (27 projects).
  - 978 MW of storage combined with generation (12 projects).
  - Almost half of all projects in Queue Cluster 7 are storage related.

# Progress has been made in the Energy Storage Interconnection Initiative

- Remains focused on ISO grid level interconnections.
  - Approach developed here may inform solutions for distribution connected storage.
- In anticipation of storage interconnection requests in Queue Cluster 7, ISO developed a framework under existing GIDAP rules for accommodating these storage interconnection requests.
  - Enables these projects to move forward while the broader spectrum of energy storage issues are identified and resolved.
  - Provides meaningful study results to these customers.

# ISO made its Order 792 compliance filing 8/4/14

- Among other things, Order 792 directed transmission providers to specifically define electric storage devices as generating facilities that can take advantage of generator interconnection procedures.
- ISO incorporated the tariff revisions set forth in Order 792 into the definition of the term Generating Facility in appendix A of the ISO tariff (also appendices EE and FF).

**Generating Facility** shall mean the Interconnection Customer's Electric Generating Unit(s) used for the production and/or storage for later injection of electricity identified in the Interconnection Customer's Interconnection Request, but shall not include the Interconnection Customer's Interconnection Facilities.

# Are changes to the GIDAP needed?

- Thus far, no changes to the GIDAP have been identified as necessary to accommodate storage interconnection to the ISO grid.
  - Need for any changes to pro forma interconnection agreement to address charging functions still under consideration.
- To the extent this initiative identifies needed changes, we have been targeting the November 2014 ISO Board meeting for approval of any needed tariff changes.
- If stakeholders believe changes to the GIDAP are needed to accommodate energy storage interconnection to the ISO grid, ISO requests that stakeholders describe these in their August 20 comments.

# Energy Storage Roadmap

- Separate from this interconnection initiative, ISO is partnering with CPUC and CEC on the development of an energy storage roadmap to address the much broader spectrum of energy storage issues.
- Objective is to understand needed policy and regulatory actions to facilitate expansion of energy storage in California.
- Will serve to enhance understanding of challenges and barriers for energy storage.
- Two stakeholder workshops will be held with the first scheduled for September 4 at the ISO.
- Publication of final roadmap by the end of the year.

# Applying the GIDAP to Cluster 7 energy storage projects

# General approach

- Existing GIDAP rules can accommodate Cluster 7 storage projects that want to be treated as generators for both aspects of their operation.
  - A generator that produces positive output during discharge mode and negative output during charging mode.
  - Must respond to ISO dispatch instructions, including curtailment to manage congestion, during both charging and discharging modes.
- This approach may be used for stand-alone storage and storage combined with a generator, but not storage combined with load.

# Payments and charges applicable to demand

- This approach of treating both the discharging and charging modes under a generator construct is being used for purposes of the interconnection process.
- This approach is not intended to determine what payments and charges beyond the interconnection process should be applicable to the charging mode.
- The determination of whether energy storage charging should be treated as demand for cost responsibility purposes is beyond the scope of this initiative.

# Requests for flexibility to charge at any time

- GIDAP will not be utilized to assess requests to obtain a higher level of service for charging mode – i.e., comparable to firm load service.
- GIDAP study process and cost responsibility framework does not apply to firm load.
- The interconnection customer must seek such firm load service from the PTO through means other than the GIDAP.
- Study scope and costs for firm load are a matter between the customer and the PTO.
- ISO does not support including unrestricted charging load in load forecasts as part of the grid expansion process.

# Reliability studies

## Discharging mode

- Studied at maximum net output MW specified in the interconnection request.
- Peak and off-peak are studied.
  - Energy storage facilities, together with other generating facilities in the electrical vicinity, are typically dispatched at maximum output level to stress the transmission system.
- Study results will provide information regarding potential overload issues under assumed conditions.
  - Includes network upgrade requirements (i.e., RNUs).

# Reliability studies (continued)

## Charging mode

- Studied at maximum steady-state charging rate.
- Peak or partial-peak, and off-peak are studied.
  - Depending on the circumstances of the energy storage facility, a worst case scenario between peak and partial-peak will be studied.
  - For example, storage located inside a load pocket and providing regulation is likely to charge during the peak hours (for this case charging during peak is the worst case condition).
  - As another example, storage to relieve over-generation situations are more likely to charge during partial-peak hours.
  - Other generating facilities in the electrical vicinity are typically dispatched at output levels lower than the maximum to stress the transmission system.

# Reliability studies (continued)

## Charging mode (continued)

- Study results will provide information regarding potential overload issues under assumed conditions.
  - Network upgrades, if any, will be identified for reliable interconnection. May include SPS.
  - It is unlikely for any such requirements to be identified that are in addition to or beyond the RNUs required for discharge mode.
  - Network upgrades to relieve operational limitations will not be identified if congestion management is the appropriate mitigation measure.

# Deliverability studies

- For system and local RA qualification.
- Only considers discharging mode.
- Maximum positive output tested for deliverability is the four-hour capacity (i.e., storage capability in MWh divided by four).
- Given existing resource adequacy rules, the conventional approach will be used of studying the four-hour capacity at summer peak conditions.
- Off-peak conditions are also assessed for storage located in a wind generation area.

# Review of existing processes for project modification

# Project modification processes

- Developers may want to modify existing projects to add storage.
- Two existing processes are available for requesting project modification:
  - Modification request process (aka “MMA”) for projects in the queue.
  - Independent study behind-the-meter expansion process for projects that have achieved COD.
- ISO is applying these existing processes on a case-by-case basis in response to requests received.
- This experience will help identify any changes that may be needed (not intending to propose any changes to either process at this time).

# Resource adequacy-related interconnection issues

# Overview of resource adequacy issues

## Interconnection context:

- Alignment of ISO deliverability study methodology with RA counting rules.

## Discussion topics:

- What is EFC and how is it determined?
- EFC and NQC (bundled vs unbundled)
- An alternative interconnection option
- Assessing the ability of a storage resource to charge

# Qualification for system or local RA

- Based on current methodologies for determining QC and NQC.
- QC is equal to the maximum output sustainable for 4 hours per existing CPUC counting rules.
- NQC determination: ISO modeling assumptions used align with the CPUC QC counting rules.
- ISO deliverability study methodology is aligned with current CPUC rules.

# Determining a storage resource's effective flexible capacity (EFC)

- Conventional resources providing flexible RA capacity requires EFC be less than or equal to NQC.
- Storage resources may count capacity value for both its discharging and charging mode.
  - Under current CPUC rules, EFC is the greater of NQC and  $(\text{NQC} - P_{\text{min}_{\text{RA}}})$ .
  - For storage,  $P_{\text{min}_{\text{RA}}}$  is a negative MW value at which the facility is capable of charging for 1.5 or more uninterrupted hours.
- Storage resources may count for a larger MW amount of flexible capacity than it might as system or local RA.
  - EFC is the difference between the NQC and  $P_{\text{min}_{\text{RA}}}$  (for storage it is the sum due to subtraction of a negative value).

# Determination of EFC for storage resources

- CPUC EFC calculation for a storage facility is made by adding the flexibility value of its charging mode ( $P_{\min_{RA}}$ ) over 1.5 hours to its discharge value (NQC).
- ISO's FRACMOO proposal only considers the change in output a resource can provide over 3 hours.
  - No distinction between charging or discharging.

# Consideration of a storage resource addressing a flexible capacity need

- A storage resource may have an EFC amount that reflects both its charging and discharging modes.
- It may be most beneficial to the system to use this capacity to
  - raise the “belly of the duck” by charging when solar energy on the grid is plentiful, and
  - then to support the upward ramp by discharging as net load increases in later afternoon.
- Thus the EFC value of the resource may be fully utilized for system benefits without the resource having to deliver energy during peak load conditions.

# Qualifying for flexible capacity

- Under current CPUC rules, a facility must be qualified for system or local RA in order to provide flexible RA.
- Implication for ISO deliverability studies:
  - Study the resource for deliverability for system and local RA (as is done today), and
  - Perform whatever additional study is needed regarding its flexibility.
- ISO may need to modify a resource's  $P_{\min_{RA}}$  due to transmission constraints
  - A methodology would need to be developed for this.

# Connection between system/local RA and flex RA

- CPUC RA decision states that flexible capacity must remain “bundled” with system/local capacity for procurement purposes.
  - Resources that wish to sell EFC must also already qualify to sell RA.
- Question: Might “unbundling” flexible capacity from system/local offer alternative interconnection options?
  - May want to consider options for storage resources that will be used only during off-peak hours for flexibility (rather than at peak as if it were providing system/local RA).
- “Unbundling” could allow a facility to provide flexible capacity without necessarily providing system or local RA as well.

# An potential alternative interconnection option

- A storage resource might provide flexible capacity without having to deliver at peak system conditions.
  - Requires that flex RA be “unbundled” from system/local RA.
- This may suggest an alternative interconnection study path for flexible-only status.
  - Might there be storage resources with characteristics and business model that may align with “flexible-only” status?
- In contrast, if no “unbundling” then a storage resource would need to obtain full capacity deliverability status through GIDAP in order to provide flexible capacity.

# Additional considerations

- Additional study methodologies may need to be considered for storage facilities that only provide regulation energy management (REM).
  - CPUC rules do not currently allow for REM flexible capacity resources.

# Charging considerations for RA resources

- SCE concern: In order to be able to discharge to provide its full RA value, a storage resource must be able to fully charge at some time during each 24-hour day.
  - SCE suggests that the interconnection study process should test to ensure that this is possible (i.e., a “charging deliverability assessment”).
- ISO position: Charging mode of a storage resource is analogous to a conventional generator acquiring needed fuel on a daily basis (this is consistent with treatment of storage under the generator construct).
  - The ISO does not try to address availability of fuel in interconnection studies.

## Next steps

Date	Milestone
August 20	Stakeholder comments due

- Please comment on information presented and discussed during the August 13 stakeholder meeting.
- Please use the comment template provided.
- Submit to [EnergyStorage@CAISO.COM](mailto:EnergyStorage@CAISO.COM) no later than 5pm on Wednesday, August 20.